



THE SCHEDULE  
FORM-A

(Form of application under Sub-Section (1) Sub-Section (2) of Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965.(Madras Act XIII of 1965) referred to in Rule 3 of the TamilNadu Public Buildings (Licensing) Rules 1996)

From

The Correspondent  
St.Joseph International Senior Secondary school ( CBSE Syllabus)  
S.F.No. 89/1,90/3A & 90/3B,  
Rameswaram Highway  
Kodikkottai Village, Maviduthikkottai Panchayat  
Devakottai Taluk  
Sivagangai District

To  
The Competent Authority

The Thasildhar  
Devakottai


Sir

I intend to use the building/to continue to use the existing Public building not at present used as a public building, which is situated in the site of Plot or S.F.No.89/1,90/3A & 3B, Rameswaram Highway, Kodikkottai in the ward or division /village/district of SIVAGANGA and specified in the statement enclosed as a public building for a period of 3 years and from the 10.02.2022 to 09.02.2025

2. The year of Construction and the present approximate Cost of Construction And the purpose for which it is to be used or is being used as a Public bldgs Are also furnished in the statement accompanying this application.

3. I enclose a Chelan for Rs.1000/-

4. I also enclose Certificate of Structural soundness in the prescribed form  
Furnished by the Engineer Shri. A.BALASUBRAMANIAN-PANEL ENGINEER  
GRADE-IA (Any amount), Approved by the SIVAGANGA District Collector thro  
Proceedings No. D.Dis.H2.12026/05, Dated 18.07.2005.

  
Signature of the owner of the bldg

Date:

- Enclosures:
1. Statement
  2. Original Chelan for Rs.1000/- Towards the application fee.


STATEMENT ACCOMPANYING FORM-A

1. Door Number of the Building : S.F.No.89/1,90/3A & 90/3B
2. Location (st.No.ward.No,Name of Place ie Corporation/Municipality/ Panchayat/Panchayat Union/ Contonment : Rameswaram Highway  
: Kodikkottai Village  
: Maviduthikkottai Panchayat  
: Devakottai Taluk
3. Year of construction : GF & FF--2015-16, SF--2017
4. App.Cost of Constn as per current rate : Rs. 2,65,00,000/-
5. Purpose for which this building is Being used or proposed to be used : To run an International Senior  
: Secondary School (CBSE Syllabus )
6. Purpose for which this bldg has Hither to been used : ...do.....
7. Details of Constn of the bldg (parti -Culars of the foundation and specfn Of the various parts under)
  1. Foundation : Individual Column Footing
  2. Basement : ...do.....
  3. Superstructure : SB in CM
  4. Floor & roof are to be given : Cement floor , RCC Roof
8. Period for which the License is Required : 3 years
9. Number of Persons to be Accommodated : 600 Students

Date : 10.02.2022

  
Signature of the Engineer  
**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - 1A,**  
**49, MUNESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**

Certified that no addition or alteration has been made to the ~~Medina~~ bldg for which this application has been made. I undertake to obtain a fresh license, incase any addition or alteration is made to the extg bldg or portion of a bldg.I also undertake to obtain a fresh license,if the purpose for which the license was granted for the use of the building or a portion of the bldg originally is changed or altered subsequently.

  
Signature of the owner of the Building.

ANNEXURE TO FORM-B

(Statement to accompany the Certificate of structural soundness)

01. Location of the building : St. Joseph International Senior  
Door No, Street No and : Secondary School (CBSE Syllabus)  
Name of Place : S.F.No. 89/1,90/3A & 90/3B  
: Rameswaram Highway  
: Kodikkottai Village  
: Maviduthikkottai Panchayat  
: Devakottai Taluk  
: Sivaganga District
02. Number, Age of the Building : One -07 years (Max)
03. Short Description of structures  
Steel/RCC framed or Load :  
Bearing walls : RCC Framed
04. Purpose for which the Building is : To run an International Senior  
Certified for use : Secondary School (CBSE Syllabus)
05. The Period for which the building  
Will be structurally sound : 3 years
06. Number of Persons to be  
Accommodated : 600 Students
07. Remarks : Form E & Declaration is attached  
: This report is prepared on the basis  
: Of the soil Test conducted by the  
: Mount Zion College of Engg & Tech  
: Pilivalam, Pudukkottai Dist thro  
: Ref.No.MZCET/03/15-16 dated  
: 02.06.2016.

Date : 10.02.2022



Signature of the Engineer

**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - IA,**  
**49, MUNESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

A. BALASUBRAMANIAN  
B.E., M.I.E., F.I.V.  
CHARTERED ENGINEER  
PANEL ENGINEER GRADE - IA  
49, MUNESWARAN KOIL STREET  
KARAIKUDI - 630 001  
Mobile: 94422 37183

FORM-B

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.

1. Foundation :

- |      |   |                       |
|------|---|-----------------------|
| i.   | Depth below Ground Level                                    | : 180 cm              |
| ii.  | Nature of Soil met with at foundation level                 | : Medium Clay soil    |
| iii. | Pressure at Foundation                                      | : 09.00 T/sqm         |
| iv.  | Probable SBC of the treatment met with At foundation level. | : 10.30 T/sqm @ 6' ht |

2. Superstructure :

- |     |  |                  |
|-----|--|------------------|
| i.  | Max.stress in the most critical section of                       |                  |
|     | Masonry  | : 16.00 Kg/sqcm  |
|     | Concrete   | : 23.00 Kg/sqcm  |
| ii. | Nature of masonry and Concrete and its Safe permissible stresses |                  |
|     | Masonry  | : 35.00 Kg/sqcm  |
|     | Concrete   | : 150.00 Kg/sqcm |

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be Granted for the period of 3 years from the 10.02.2022 to the 09.02.2025 inclusive of this date.

A. BALASUBRAMANIAN  
B.E., M.E., F.I.V.,  
Date: 10.02.2022  
CHARTERED ENGINEER,  
PANEL ENGINEER GRADE - IA,  
49, MUNEESWARAN KOIL STREET,  
KARAIKUDI - 630 001  
Mobile: 94422 37183



Signature of the Engineer.

**A. BALASUBRAMANIAN,**  
**B.E., M.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - IA,**  
**49, MUNEESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

FORM-C

(Form of Certificate of structural Soundness under Sub-Section (4) of the Section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (TamilNadu Act 13 of 1965 referred to in rule 4 of the TamilNadu Public Buildings (Licensing) Rules 1966.)

I certify that I have inspected the building, mentioned in the statement and furnish below The salient technical features.

1. Foundation :


- i. Depth below Ground Level : 180 cm
- ii. Nature of Soil met with at foundation level : Medium Clay Soil
- iii. Pressure at Foundation : 09.00 T/sqm
- v. Probable SBC of the treatment met with At foundation level. : 10.30 T/sqm @ 6'ht

2. Superstructure :

- i. Max stress in the most critical section of
  - Masonry : 16.00 Kg/sqcm
  - Concrete : 23.00 Kg/sqcm
- ii. Nature of masonry and Concrete and its Safe permissible stresses
  - Masonry : 35.00 Kg/sqcm
  - Concrete : 150.00 Kg/sqcm

The structural soundness of the building has been verified by me with reference to ISI Loading Standards 875 (Latest Version) and other relevant Indian Standards Code of Practice and I Declare that the Building is structurally Sound to be used as a Public Building for the purpose noted in the statement. A license may be Granted for the period of 3 years from the 10.02.2022 to the 09.02.2025 inclusive of this date.

A. BALASUBRAMANIAN  
B.E., M.I.E., F.I.V.,  
CHARTERED ENGINEER,  
PANEL ENGINEER GRADE - 1A,  
49, MUNEESWARAN KOIL STREET,  
KARAIKUDI - 630 001.  
Mobile: 94422 37183



Signature of the Engineer.

**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - 1A,**  
**49, MUNEESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

STATEMENT TO ACCOMPANY THE OPINION REGARDING STRUCTURAL SOUNDNESS

- |     |   |   |
|-----|---|---|
| 01. | Location of the building<br>Door No, Street No and<br>Name of Place           | : St Joseph International Senior<br>: Secondary School (CBSE Syllabus)<br>: S.F.No. 89/1,90/3A & 90/3B<br>: Rameswaram High way<br>: Kodikkottai Village<br>: Maviduthikkottai Panchayat<br>: Devakottai Taluk<br>: Sivaganga District            |
| 02. | Number, Age of the Building   | : One ---07 years ( max)  |
| 03. | Number of Stories   | : Ground to Second floor only   |
| 04. | Short Description of structures.<br>Steel/RCC framed or Load<br>Bearing walls | : RCC Framed  |
| 05. | Purpose for which the Building is<br>Certified for use                        | : To run an International Senior<br>: Secondary School (CBSE Syllabus)  |
| 06. | The Period for which the building<br>Will be structurally sound               | : 3 years   |
| 07. | Number of Persons to be<br>Accommodated                                       | : 600 Students  |
| 08. | Remarks   | : Form E & Declaration is attached<br>: This report is prepared on the basis<br>: Of the soil Test conducted by the<br>: Mount Zion College of Engg & Tech<br>: Pilivalam, Pudukkottai Dist thro<br>: Ref.No.MZCET/03/15-16 dated<br>: 02.06.2016 |

Date : 10.02.2022



Signature of the Engineer

**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - 1A,**  
**49, MUNEESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

A. BALASUBRAMANIAN  
B.E., M.I.E., F.I.V.  
CHARTERED ENGINEER  
PANEL ENGINEER GRADE - 1A  
49, MUNEESWARAN KOIL STREET  
KARAIKUDI - 630 001  
Mobile: 94422 37183

FORM- E

{(Form of report to be made to the competent authority by inspecting authorities or officers Appointed under Other Acts Under section 28 of the Tamilnadu Public Buildings ( Licensing)Act 1965 (Madras Act XIII of 1965) referred to in rule 7 of the Tamilnadu Public Buildings (Licensing) Rules, 1966)}

- |  |   |
|--|---|
| 1. Name and designation of inspecting authority or Officer appointed or having jurisdiction under Any other Act or Law           | : A Balasubramanian., B.E., M.I.E, M.Sc,<br>: Panel Engineer Grade-1A (Any amount)<br>: Sivaganga District  |
| 2. Location of the Building inspected ( Door No. Street Number, Name of Place ie Municipal Corporation/Municipality/Panchayat or | : St.Joseph International Senior Sec School<br>: S.F.No.89/1, 90/3A & 90/3B<br>: Rameswaram Highway<br>: Kodikkottai Village<br>: Maviduthikottai Panchayat<br>: Devakottai Taluk<br>: Sivaganga District |
| 3. Date of Inspection  | : 07.02.2022<br>: Date of issue of Certificate<br>: 10.02.2022  |
| 4. Purpose for which the building is used  | : To run an International<br>: Senior Secondary School etc  |
| 5. Nature of defects noticed   | : Nil   |
| 6. Suggestions for rectifying defects  | : Nil   |
| 7. If in a dangerous condition, immediate Steps recommended to be taken  | : Refer the SSC & Declaration etc   |



Signature of the inspecting authority or  
Officer appointed or having jurisdiction

**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - 1A,**  
**49, MUNEESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

DECLARATION BY THE PANEL ENGINEER GRADE-1A ( Any amount)

St.JOSEP INTERNATIONAL SENIOR SECONDARY SCHOOL,  
S.F.No.89/1,90/3A & 90/3B, Rameswaram Highway,Kodikkottai Village  
Maviduthikottai Panchayat, Devakottai Taluk, Sivaganga District

---

This Report does not include any eventualities caused due to natural calamities.

We hereby advise that periodical repairs and renovations shall be carried out to the entire building Blocks regularly every year by intimating me thro writing.

Further necessary fire fighting equipments should be kept in the premises and should be trained for Operation. If any fire accident/mishap occurs we are not held responsible.

Structural alteration/deviation should not be carried out to a part of whole building without prior permission from me.

Emergency exits to be provided as per norms.

All electrical points, wiring/Gadgets has to be checked properly and to be maintained periodically- this Competent Engineer is not held responsible for electrical defaults & short circuits.

If any violation is found at a later stage after issue of this report we are not held responsible and this report gets cancelled. The lessee has to adhere the legal frame work and then only this Certificate is Valid.

Further this report covers the certified blocks & floors only-Legal aspects not considered.

Date of Inspection: 07.02.2022

Date : 10.02.2022



Signature of the inspecting authority or  
Officer appointed or having jurisdiction  
**A. BALASUBRAMANIAN,**  
**B.E., M.I.E., F.I.V.,**  
**CHARTERED ENGINEER,**  
**PANEL ENGINEER GRADE - 1A,**  
**49, MUNEESWARAN KOIL STREET,**  
**KARAIKUDI - 630 001.**  
**Mobile: 94422 37183**

Copy to

1. P.A. to the Collector- Sivaganga
2. R.D.O.—Devakottai

**PROCEEDINGS OF THE TAHSILDAR, DEVAKOTTAI**

**PRESENT: Thiru.S.ANTHONY RAJ.,**

K.DIS. B4/718/2022

Dated: 17.02.2022

**FORM - D**

Form of License under the sub-section (1) of section 6 of Tamilnadu Public Building (Licensing) Act 1965 (Tamilnadu Act 13 of 1965) referred to in Rule 6 of the Tamilnadu Public Building (Licensing) Rules 1956.

**LICENCE**

License No: 05  
Register No: 05/2022  
Fee Paid : Rs.5,000 (Rupees Five Thousand Only)  
Challan No.20220214001520 Dated:14.02.2022

License is hereby granted to The Principal, St.Joseph International School, Maviduthikottai Panchayat, Kodikottai Village, Puliya Firka, Devakottai Taluk, Sivagangai District. The building license granted is renewed for a period of Three years from 10.02.2022 to 09.02.2025 in respect of the building specified in the statement furnished below and subject of the conditions and period mentioned hereunder

TAHSILDAR,  
DEVAKOTTAI.

**(STATEMENT TO ACCOMPANY THE LICENCE)**

1. Name of the address of the owner of the Building : The Principal,  
St.Joseph International School,  
Kodikottai village, Puliya Firka,  
Devakottai Taluk,  
Sivagangai District
2. Location of the Building (Survey No) : St.Joseph International School,  
(S.No-89/1,90/3A&90/3B)  
Kodikottai village, Puliya Firka,  
Devakottai Taluk,
3. Purpose for which the building Block New Building (Concrete) : To Run a ST.JOSEPH  
INTERNATIONAL SCHOOL
4. No. of persons to be accommodated : 600 STUDENTS  
Period of license : 10.02.2022 to 09.02.2025  
(Three years)

TAHSILDAR,  
DEVAKOTTAI

To  
The Principal,  
St.Joseph International School,  
Kodikottai village, Puliya Firka,  
Devakottai Taluk,  
Sivagangai District.

